

STATUS

TENDER ISSUE

NOTES

1. THE REMOVAL OF THE EXISTING NCA AND NCA POLES SUBJECT TO HERITAGE AND NCA APPROVAL.
2. FOOTING DETAILS TO BE AS PER CERTIFIED STRUCTURAL ENGINEER AND POLE MANUFACTURER RECOMMENDATIONS.
3. FINISH OF POLES TO BE DULUX DURALLOY ANOTEK DARK GREY MATT 451275 POWDERCOATED. THIS IS TO BE CONFIRMED BY THE NCA, NCA AND HERITAGE CONSULTANTS.
4. THE CONTRACTOR IS TO PROVIDE A WORKSHOP DRAWING OF THE POLE AND FOOTING DETAIL FOR REVIEW.
5. DATA ENABLER AND WIRELESS ETHERNET RECEIVER TO BE HOUSED INSIDE BASE OF POLE - NEAR ACCESS HATCH. PROVISION TO BE MADE INSIDE POLE FOR MOUNTING THIS CONTROL GEAR.
6. INSTALLATION OF LUMINAIRES, ACCESSORIES AND CONTROL GEAR BY INSTALLATION CONTRACTOR.
7. FINAL ADJUST OF LUMINAIRES TO BE CONDUCTED BY STEENSEN VARMING DURING COMMISSIONING OF THE LIGHTING INSTALLATION. (REFER TO THE LIGHTING SPECIFICATION FOR CONTRACTOR'S RESPONSIBILITIES DURING COMMISSIONING).
8. ALL WORKS TO BE INSTALLED IN ACCORDANCE WITH AS3000:2007.

| AMENDMENTS | | |
|------------|----------------------|----------|
| REV | DESCRIPTION | DATE |
| A | TENDER ISSUE | 20.02.14 |
| B | REVISED TENDER ISSUE | 15.04.14 |
| C | REVISED TENDER ISSUE | 08.09.14 |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

Copenhagen London Sydney Hong Kong New York
 8, 9 Castlereagh St. Sydney, NSW, 2000, Australia
 ABN 50 001 189 037
 t : +61 / 02 9967 2200
 e : info@steensenvarming.com

STEENSEN VARMING




PROJECT
**HIGH COURT OF AUSTRALIA
 FACADE LIGHTING UPGRADE**

PARKES PL. PARKES - ACT

DRAWING TITLE
**LIGHTING
 LIGHTING DETAILS - POLES 1 AND 3**

| | | | | |
|-------------|-------------|------------|---------|-----------|
| 0 0.5m 1m | | | | AO |
| CREATED | DRAWN | DESIGNED | CHECKED | |
| DEC'13 | AZ | SL | EU | |
| APPROVED | SCALE | NORTHPOINT | | |
| EU | 1 : 10 | | | |
| PROJECT No. | DRAWING No. | REVISION | | |
| 13771 | L1008 | C | | |



1 POLES 1 AND 3 FRONT VIEW
1 : 10

2 POLES 1 AND 3 SIDE VIEW
1 : 10

3 POLES 1 AND 3 ISOMETRIC VIEW